



Airport Manager's Report, 2021

February 17, 2021

- 1. Mike Barta & sons inc. annual filter change on all fuel dispensers.**
- 2. 100LL Pump needs a cover to prevent freezing and water getting into the dispenser making it INOP.**
- 3. Snow removal and snow bank removal.**
- 4. Bill approval system to insure we understand the bills to be paid.**